



1375 S. Washington Avenue, Suite 300
Lansing, Michigan 48910
517-702-0470
Fax 517-702-0477
www.triterra.us

July 8, 2019
Triterra Project #: 19-2171-03

Kalamazoo County Land Bank Authority
Attn: Mr. Kenn Hartmann
1523 Riverview Drive, Suite A
Kalamazoo, Michigan 49004

**SUBJECT: *Asbestos-Containing Materials Inspection and Hazardous Materials Survey
517 Lulu Street, Kalamazoo, Michigan 49007***

Dear Mr. Hartmann:

Triterra has completed an asbestos-containing materials (ACM) inspection and hazardous materials survey for the residential house located at *517 Lulu Street in Kalamazoo, Michigan* (the Property) to determine if any ACM or other hazardous non-ACM exist within the structure. This inspection was completed for the Kalamazoo County Land Bank Authority (the User) to ensure compliance with the OSHA Construction Standard for Asbestos (29 CFR 1926.1101) and the United States Environmental Protection Agency (USEPA) requirements for inspection of buildings prior to renovation or demolition under the National Emissions Standards for Hazardous Air Pollutants (NESHAP 40 CFR Part 61). This report outlines and interprets the results of these analyses. A description of the structure, inspection methods, results, and recommendations are provided herein.

Building Description

The Property includes a two-story, single-family residential house with an unfinished basement. The wood-frame home has a concrete block foundation, wood siding, and an asphalt shingle roof. Building materials therein include drywall and plaster walls and ceilings, various types of flooring (carpet, laminate flooring, vinyl tile), and various insulating materials (cellulose and fiberglass). Other building materials/components include acoustical ceiling tile and a gas furnace which is located in the basement.

Hazardous Materials Survey

On June 12, 2019, Greg Ross of Triterra conducted a hazardous materials survey of the Property to identify potential polychlorinated biphenyl (PCB) and mercury containing equipment as well as containers that may contain hazardous or regulated wastes. Any identified material was documented along with its approximate location within or around the structure. A summary of the hazardous materials identified at the Property is presented in Table 1.

ACM Inspection Methods

Greg Ross of Triterra completed an ACM inspection of the structure on June 12, 2019. Mr. Ross is an accredited State of Michigan/EPA Asbestos Building Inspector, certificate number A52547.

Building construction plans, diagrams, and/or User provided information were utilized to assign room/area designations so that all areas of the structure(s) are identifiable for sample location purposes. Each room/area of the structure(s) was then evaluated for suspect ACM. Areas that contain similar suspect ACM were grouped into a single Homogenous Area (a grouping of rooms/spaces containing the same material according to color, texture, and date of application).

Suspect materials were placed into three major categories: surfacing materials, thermal system insulation materials, and miscellaneous materials. Surfacing materials are sprayed-on or troweled-on (i.e. plaster, fireproofing, or acoustical materials). Thermal system insulation materials are used for heat insulation or condensation prevention (i.e. boiler coverings, pipe insulation, or roof drain insulation). Miscellaneous materials are any application that does not fall into the surfacing or thermal system insulation categories (i.e. floor tile, roofing, drywall, etc.).

Representative samples of each encountered suspect ACM were either collected for laboratory analysis or presumed to contain asbestos. Presumed asbestos-containing materials (PACM) are generally thermal system insulation and surfacing materials that have a high likelihood of containing greater than 1% asbestos, and therefore are not sampled. Each sample collected was containerized in double-layer, laboratory-provided, sampling bags. The collected samples were sent to EMSL Analytical, Inc. (EMSL) [Accreditation Number 101048-4] for analysis using polarized light microscopy (PLM). PLM is the most commonly used method for the analysis of bulk samples, using 10 to 400 times power magnification. PLM bulk sample analyses follow the EPA method of the Determination of Asbestos in Bulk Insulation Samples (EPA 600/M4-82-020). The laboratory results indicate the percentage and type of asbestos in the sample and the other fibrous or non-fibrous non-asbestos materials in the sample. Chain-of-custody documentation was followed throughout the sample collection, handling, and shipping to assure quality control requirements were met.

Inspection Results

A total of 21 suspect ACM samples from 13 homogenous areas (HA) were analyzed for the presence of asbestos or were presumed to be ACM, and therefore were not sampled. The laboratory analytical results are presented in Attachment 1. Photos of identified ACM are included in Attachment 2.

Friable ACM are defined as materials which contain 1 percent or greater asbestos that can be crushed, pulverized, or reduced to powder using hand pressure. Friable ACM identified during the inspection, include:

- **HA 9:** *Duct wrap* on a vent run in the basement (Photo 2).

Non-friable ACM are defined as materials that cannot be crumbled, pulverized, or reduced to a powder by hand pressure. Non-friable ACM is separated into category I and category II non-friable ACM.

- Category I non-friable ACM is defined as packings, gaskets, resilient floor coverings, and asphalt roofing products containing 1 percent or greater asbestos. Category I non-friable ACM identified during the inspection, include:

- **HA 3:** *Yellow/tan laminate flooring with a rectangle pattern* in the 1st floor bathroom under the 12x12-inch white floor tile (HA 2) (Photo 1);
- Category II non-friable ACM is defined as any other non-friable material containing 1 percent or greater asbestos, excluding category I non-friable ACM. No Category II non-friable ACM was identified during the inspection.

The materials sampled during the inspection are detailed in Table 2 (see Attachment 1), which includes their location, description, and ACM status.

Conclusions/Recommendations

Based on Triterra’s understanding of the demolition activities planned for the Property, proper abatement of the friable *duct wrap* (**HA 9**) is required prior to commencing these activities. Additionally, the removal of Category I non-friable materials (and non-ACM hazardous materials) is strongly recommended prior to demolition as these materials may become friable during these activities.

Depending on the type and quantities of ACM that will be removed from the structure(s), notification may need to be provided to the following regulatory agencies 10 working (or calendar) days prior to commencement of work with the submittal of a Notification of Intent to Renovate/Demolish form (EQP 5661). The retained asbestos abatement contractor should complete this form as part of their services. This notification should be provided to the Michigan Department of Environment, Great Lakes, and Energy – Air Quality Division (EGLE-AQD) and Michigan Department of Licensing & Regulatory Affairs (LARA) any time renovation/demolition/asbestos abatement is to be completed on a building.

NESHAP Asbestos Program
EGLE – AQD
P.O. Box 30260
Lansing, Michigan 48909
(517) 284-6777

LARA
MIOSHA Asbestos Program
P.O. Box 30671
Lansing, Michigan 48909
(517) 636-4551

Regulations governing employee exposure to asbestos hazards in the workplace are found in the federal regulations at Title CFR, part 1910.1001, which is the U. S. Occupational Safety and Health Administration (OSHA) asbestos standard. The presence of any ACM in a facility where there is a possibility of employee exposure triggers the applicability of the standard to the workplace and employee. The standard generally applies to labeling, signage, employee training, and personal protective equipment in order to minimize the risk of asbestos exposure. An employer is required to institute a training program for all employees who are exposed to airborne concentrations of asbestos at or above the employee permissible exposure limit and/or excursion limit and ensure employee participation in the program. Air sampling and laboratory analysis are required to determine the concentration of asbestos in the air of the employee work areas.

Disclaimer

Destructive testing was completed in accessible areas of the structure(s) and/or areas designated by the User throughout this inspection. If suspect ACMs are encountered during (demolition and/or renovation)


activities for which no analytical data exists, Triterra recommends the material(s) remain undisturbed until the asbestos content of the material(s) is determined in accordance with USEPA and OSHA regulations. Quantities presented are meant as a guide and should not be used for bidding purposes without verification.

Triterra completed the work in general conformance with federal, state, and local requirements and made all appropriate inquiry consistent with good commercial or customary practice. Triterra assumes the information provided in this report and by the User and/or property owner is factual, complete, and correct. Triterra does not warrant that this report represents an exhaustive study of all possible environmental concerns associated with asbestos at the property. However, the items included in this report are believed to adequately address the client's needs at this time.

This report was prepared exclusively for the Kalamazoo County Land Bank Authority for the purposes as expressly stated. This report may be unsuitable for other uses, and reliance on its contents by anyone other than the User is done at the sole risk of that party. This report may not be reproduced, sold, or otherwise conveyed to another entity without prior written permission from Triterra.

Should you have any questions or comments regarding this report, please feel free to contact the undersigned at (517) 702-0470.

Sincerely,

The logo for Triterra, featuring the word "TRITERRA" in a bold, sans-serif font. The letter "I" is stylized with a green and yellow square graphic element.A handwritten signature in black ink, appearing to read "Greg Ross".

Greg Ross
Environmental Technician
Michigan/EPA Certified Asbestos Inspector #A52547

A handwritten signature in blue ink, appearing to read "Alan Snell".

Alan Snell
Project Geologist
Manager | Hazardous Materials
Michigan/EPA Certified Asbestos Inspector #A47249

Attachments:

TABLES



TABLE 1
REGULATED HAZARDOUS MATERIALS

Project: 517 Lulu Street
Location: Kalamazoo, Michigan 49007
Project Number: 19-2171-03
Personnel: Greg Ross

Description of Material (hazardous component)	Container Size	Quantity	Location
Smoke detector (radioactive material)	N/A	7	Throughout home
Rubber Tire	N/A	1	Yard outside home
Fire extinguisher	N/A	1	Kitchen
Paint bucket (heavy metals)	5 Gallon	1	Basement
Paint can (heavy metals)	N/A	6	Throughout home
Mercury switch thermostat (mercury)	N/A	1	East wall of living room



TABLE 2
ASBESTOS CONTAINING MATERIAL
ANALYTICAL RESULTS

Project: 517 Lulu Street
Location: Kalamazoo, Michigan 49007
Project Number: 19-2171-03
Personnel: Greg Ross

Homogeneous Area (HA)	Sample/Material Description	Sample Identification		Location	% Asbestos Laboratory Result	ACM Classification	Approximate Quantity
1	Plaster - Base Coat Plaster - Finish Coat Texture Wallpaper	HA-1A-G	S	Walls and ceilings throughout home	<1 ND ND ND	Non-ACM	NA
2	12x12" Stickyback floor tile - white w/ diamond center	HA-2	M	Front entry, kitchen, hall near basement, and 1st floor bathroom	ND	Non-ACM	NA
3	Laminate flooring - yellow/tan w/ rectangle design	HA-3	M	1st floor bathroom under HA 2	20	Category I	45 Sq. Ft
4	3x3" Plastic tile - blue	HA-4	M	1st floor bathroom walls	ND	Non-ACM	NA
5	Laminate flooring - tan/brown w/ rock pattern Adhesive	HA-5	M	Under HA 2 in basement hall and kitchen	ND	Non-ACM	NA
6	Drywall	HA-6A-C	M	Inner walls on 2nd floor NE bedroom and hall	ND	Non-ACM	NA
7	Fiberboard	HA-7	M	2nd floor bathroom behind wood paneling	ND	Non-ACM	NA
8	Omitted - No Sample/ACM	--	--	--	--	--	--
9	Duct wrap	PACM	TSI	Basement ventilation duct	PACM	Friable	30 Sq. Ft
10	2x4' Ceiling tile - white - smooth	HA-10	M	Kitchen	ND	Non-ACM	NA
11	Blown-in insulation	HA-11	M	Attic	ND	Non-ACM	NA
12	Pink insulation	HA-12	M	Attic	ND	Non-ACM	NA
13	Brown linoleum backsplash	HA-13	M	Kitchen	ND	Non-ACM	NA
14	Roofing shingle Tar Tar Paper	HA-14	M	House roof	ND	Non-ACM	NA

Notes:

M = Miscellaneous building material
 S = Surfacing material
 TSI = Thermal system insulation

ND = None Detected
 NA = Not Applicable
 HA = Homogeneous Area

Asbestos Containing Material
 PACM = Presumed ACM

An asbestos-containing material (ACM) is defined as a material containing greater than 1% asbestos. Laboratory results reported as 1% or greater indicate an ACM. ACM identified as friable are friable by definition. ACM identified as Category I and II non-friable ACM that have a high probability of becoming crumbled, pulverized, or reduced to a powder by the forces expected to act on the materials during the course of demolition or renovation, should be removed before demolition.

ATTACHMENT 1

***EMSL ANALYTICAL RESULTS AND
CHAIN OF CUSTODY DOCUMENTATION***



EMSL Analytical, Inc.

15111 Northville Rd Plymouth, MI 48170

Tel/Fax: (734) 668-6810 / (734) 668-8532

<http://www.EMSL.com> / annarborlab@emsl.com

EMSL Order: 081901652

Customer ID: TRIA25

Customer PO:

Project ID:

Attention: Greg Ross
Triterra
1375 S. Washington Avenue
Suite 300
Lansing, MI 48910

Project: 517 Lulu St.

Phone: (517) 702-0470

Fax:

Received Date: 06/17/2019 9:00 AM

Analysis Date: 06/19/2019

Collected Date:

Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
HA-1 A <small>081901652-0001</small>	Plaster	Gray Fibrous Homogeneous	<1% Cellulose 2% Hair	7% Quartz 91% Non-fibrous (Other)	<1% Chrysotile
HA-1 B-Texture <small>081901652-0002</small>	Plaster	White Non-Fibrous Homogeneous		4% Ca Carbonate 96% Non-fibrous (Other)	None Detected
HA-1 B-Finish Coat <small>081901652-0002A</small>	Plaster	Beige Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
HA-1 B-Base Coat <small>081901652-0002B</small>	Plaster	Gray Fibrous Homogeneous	<1% Cellulose <1% Hair	7% Quartz 93% Non-fibrous (Other)	<1% Chrysotile
HA-1 C-Finish Coat <small>081901652-0003</small>	Plaster	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
HA-1 C-Base Coat <small>081901652-0003A</small>	Plaster	Gray Fibrous Homogeneous	<1% Cellulose <1% Hair	7% Quartz 93% Non-fibrous (Other)	<1% Chrysotile
HA-1 D <small>081901652-0004</small>	Plaster	Gray Fibrous Homogeneous	<1% Cellulose <1% Hair	7% Quartz 93% Non-fibrous (Other)	<1% Chrysotile
HA-1 E-Wallpaper <small>081901652-0005</small>	Plaster	Brown Fibrous Homogeneous	95% Cellulose	5% Non-fibrous (Other)	None Detected
HA-1 E-Finish Coat <small>081901652-0005A</small>	Plaster	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
HA-1 E-Base Coat <small>081901652-0005B</small>	Plaster	Gray Fibrous Homogeneous		6% Quartz 94% Non-fibrous (Other)	<1% Chrysotile
HA-1 F-Finish Coat <small>081901652-0006</small>	Plaster	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
HA-1 F-Base Coat <small>081901652-0006A</small>	Plaster	Gray Fibrous Homogeneous		8% Quartz 92% Non-fibrous (Other)	<1% Chrysotile
HA-1 G-Finish Coat <small>081901652-0007</small>	Plaster	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
HA-1 G-Base Coat <small>081901652-0007A</small>	Plaster	Tan Fibrous Homogeneous		9% Quartz 91% Non-fibrous (Other)	<1% Chrysotile
HA-2 <small>081901652-0008</small>	Floor Tile	Gray/Black Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
HA-3 <small>081901652-0009</small>	Laminate Floor	Gray/Tan/White Fibrous Heterogeneous		80% Non-fibrous (Other)	20% Chrysotile

Initial report from: 06/19/2019 17:00:56



EMSL Analytical, Inc.

15111 Northville Rd Plymouth, MI 48170

Tel/Fax: (734) 668-6810 / (734) 668-8532

<http://www.EMSL.com> / annarborlab@emsl.com

EMSL Order: 081901652

Customer ID: TRIA25

Customer PO:

Project ID:

Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
HA-4 <i>081901652-0010</i> <i>Plastic is a non suspect material, only adhesive analyzed.</i>	Plastic Tile	Tan/Beige Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
HA-5-Linoleum <i>081901652-0011</i>	Laminate Floor	Gray/Tan Fibrous Heterogeneous	20% Cellulose 3% Glass	77% Non-fibrous (Other)	None Detected
HA-5-Adhesive <i>081901652-0011A</i>	Laminate Floor	Beige Non-Fibrous Homogeneous	<1% Cellulose	100% Non-fibrous (Other)	None Detected
HA-6 A <i>081901652-0012</i>	Drywall	Gray Non-Fibrous Homogeneous	4% Cellulose <1% Glass	96% Non-fibrous (Other)	None Detected
HA-6 B <i>081901652-0013</i>	Drywall	Brown/Gray Fibrous Heterogeneous	4% Cellulose <1% Glass	96% Non-fibrous (Other)	None Detected
HA-6 C <i>081901652-0014</i>	Drywall	Brown/Gray Fibrous Heterogeneous	4% Cellulose	96% Non-fibrous (Other)	None Detected
HA-7 <i>081901652-0015</i>	Fiberboard	Brown/Black/Blue Fibrous Heterogeneous	65% Cellulose	35% Non-fibrous (Other)	None Detected
HA-10 <i>081901652-0016</i>	Ceiling Tile	Gray/White Fibrous Homogeneous	55% Cellulose 5% Min. Wool	30% Perlite 10% Non-fibrous (Other)	None Detected
HA-11-Insulation A <i>081901652-0017</i>	Insulation	Brown/Tan Fibrous Homogeneous	95% Cellulose	5% Non-fibrous (Other)	None Detected
HA-11-Insulation B <i>081901652-0017A</i>	Insulation	Peach Fibrous Homogeneous	10% Cellulose 85% Glass	5% Non-fibrous (Other)	None Detected
HA-12-Insulation A <i>081901652-0018</i>	Insulation	Pink Fibrous Homogeneous	5% Cellulose 90% Glass	5% Non-fibrous (Other)	None Detected
HA-12-Insulation B <i>081901652-0018A</i>	Insulation	Brown/Tan Fibrous Homogeneous	95% Cellulose	5% Non-fibrous (Other)	None Detected
HA-13-Linoleum <i>081901652-0019</i>	Back Splash	Gray/White Fibrous Heterogeneous	15% Cellulose 3% Glass	82% Non-fibrous (Other)	None Detected
HA-13-Adhesive <i>081901652-0019A</i>	Back Splash	Beige Non-Fibrous Homogeneous	5% Cellulose	95% Non-fibrous (Other)	None Detected
HA-14-Shingle <i>081901652-0020</i>	Roofing	Black Fibrous Heterogeneous	6% Glass	94% Non-fibrous (Other)	None Detected
HA-14-Tar <i>081901652-0020A</i>	Roofing	Black Non-Fibrous Homogeneous	2% Cellulose	98% Non-fibrous (Other)	None Detected
HA-14-Tar Paper <i>081901652-0020B</i>	Roofing	Black Fibrous Heterogeneous	65% Cellulose	35% Non-fibrous (Other)	None Detected

Initial report from: 06/19/2019 17:00:56



EMSL Analytical, Inc.

15111 Northville Rd Plymouth, MI 48170

Tel/Fax: (734) 668-6810 / (734) 668-8532

<http://www.EMSL.com> / annarborlab@emsl.com

EMSL Order: 081901652

Customer ID: TRIA25

Customer PO:

Project ID:

Analyst(s)

Rebecca Newman (25)

Ryan Shannon (8)



Ryan Shannon, Laboratory Manager
or Other Approved Signatory

EMSL maintains liability limited to cost of analysis. The above analyses were performed in general compliance with Appendix E to Subpart E of 40 CFR (previously EPA 600/M4-82-020 "Interim Method"), but augmented with procedures outlined in the 1993 ("final") version of the method. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. All samples received in acceptable condition unless otherwise noted. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. EMSL recommends gravimetric reduction for all non-friable organically bound materials prior to analysis. Estimation of uncertainty is available on request.

Samples analyzed by EMSL Analytical, Inc. Plymouth, MI NVLAP Lab Code 101048-4

Initial report from: 06/19/2019 17:00:56



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS DIVISION

Asbestos Chain of Custody

EMSL Order Number (Lab Use Only):

081901652

PHONE:
FAX:

Company Name : Triterra		EMSL Customer ID:	
Street: 1375 S. Washington Ave, Suite 300		City: Lansing	State/Province:
Zip/Postal Code: 48910	Country: United States	Telephone #: 517-702-0470	Fax #: 517-702-0477
Report To (Name): Greg Ross		Please Provide Results: <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email	
Email Address: Greg.Ross@Triterra.US		Purchase Order:	
Project Name/Number: 517 Lulu St		EMSL Project ID (Internal Use Only):	
U.S. State Samples Taken:		CT Samples: <input type="checkbox"/> Commercial/Taxable <input type="checkbox"/> Residential/Tax Exempt	
EMSL-Bill to: <input type="checkbox"/> Same <input type="checkbox"/> Different - If Bill to is Different note instructions in Comments** <i>Third Party Billing requires written authorization from third party</i>			
Turnaround Time (TAT) Options* - Please Check			
<input type="checkbox"/> 3 Hour <input type="checkbox"/> 6 Hour <input type="checkbox"/> 24 Hour <input type="checkbox"/> 48 Hour <input checked="" type="checkbox"/> 72 Hour <input type="checkbox"/> 96 Hour <input type="checkbox"/> 1 Week <input type="checkbox"/> 2 Week			
*For TEM Air 3 hr through 6 hr, please call ahead to schedule. **There is a premium charge for 3 Hour TEM AHERA or EPA Level II TAT. You will be asked to sign an authorization form for this service. Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide.			
PCM - Air <input type="checkbox"/> Check if samples are from NY <input type="checkbox"/> NIOSH 7400 <input type="checkbox"/> w/ OSHA 8hr. TWA	TEM - Air <input type="checkbox"/> 4-4.5hr TAT (AHERA only) <input type="checkbox"/> AHERA 40 CFR, Part 763 <input type="checkbox"/> NIOSH 7402 <input type="checkbox"/> EPA Level II <input type="checkbox"/> ISO 10312	TEM- Dust <input type="checkbox"/> Microvac - ASTM D 5755 <input type="checkbox"/> Wipe - ASTM D6480 <input type="checkbox"/> Carpet Sonication (EPA 600/J-93/167)	
PLM - Bulk (reporting limit) <input checked="" type="checkbox"/> PLM EPA 600/R-93/116 (<1%) <input type="checkbox"/> PLM EPA NOB (<1%) Point Count <input type="checkbox"/> 400 (<0.25%) <input type="checkbox"/> 1000 (<0.1%) Point Count w/Gravimetric <input type="checkbox"/> 400 (<0.25%) <input type="checkbox"/> 1000 (<0.1%) <input type="checkbox"/> NYS 198.1 (friable in NY) <input type="checkbox"/> NYS 198.6 NOB (non-friable-NY) <input type="checkbox"/> NYS 198.8 SOF-V <input type="checkbox"/> NIOSH 9002 (<1%)	TEM - Bulk <input type="checkbox"/> TEM EPA NOB <input type="checkbox"/> NYS NOB 198.4 (non-friable-NY) <input type="checkbox"/> Chatfield SOP <input type="checkbox"/> TEM Mass Analysis-EPA 600 sec. 2.5	Soil/Rock/Vermiculite <input type="checkbox"/> PLM EPA 600/R-93/116 with milling prep (<1%) <input type="checkbox"/> PLM EPA 600/R-93/116 with milling prep (<0.25%) <input type="checkbox"/> TEM EPA 600/R-93/116 with milling prep (<0.1%) <input type="checkbox"/> TEM Qualitative via Filtration Prep <input type="checkbox"/> TEM Qualitative via Drop Mount Prep <input type="checkbox"/> Cincinnati Method EPA 600/R-04/004 - PLM/TEM (BC only)	
<input checked="" type="checkbox"/> Check For Positive Stop - Clearly Identify Homogenous Group		Filter Pore Size (Air Samples): <input type="checkbox"/> 0.8µm <input type="checkbox"/> 0.45µm	
Samplers Name: Greg Ross		Samplers Signature:	
Sample #	Sample Description	Volume/Area (Air) HA # (Bulk)	Date/Time Sampled
HA-1A	Plaster	1	6/12/19
HA-1B	''	1	
HA-1C	''	1	
HA-1D	''	1	
HA-1E	''	1	
Client Sample # (s):		Total # of Samples: 20	
Relinquished (Client):		Date: 6/12/19	Time: 6:00
Received (Lab): RN FE		Date: 6/17/19	Time: 9:00
Comments/Special Instructions:			



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Asbestos Chain of Custody
EMSL Order Number (Lab Use Only):

081901652

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Sample #	Sample Description	Volume/Area (Air) HA # (Bulk)	Date/Time Sampled
HA-1 f	Plaster	1	6/12/19
HA-1 G	"	1	
HA-2	12x12" floor tile white/pink	2	
HA-3	Laminate flooring yellow/brown	3	
HA-4	3x3" blue plastic tiles	4	
HA-5	Laminate flooring rock pattern	5	
HA-6 A	Drywall	6	
HA-6 B	"	6	
HA-6 C	"	6	
HA-7	fiberboard	7	
HA-10	Ceiling tile white, smooth	10	
HA-11	Blown Insulation	11	
HA-12	Pink Insulation	12	
HA-13	Brick splash, brown	13	
HA-14	Roofing	14	

*Comments/Special Instructions:

FE

RNI 6/17/19 9:00

ATTACHMENT 2

SITE PHOTOGRAPHS



PHOTO: 1 **DATE: 6/12/2019** **BY: Greg Ross**
SUBJECT: HA 3: Asbestos-containing yellow/tan laminate flooring with a rectangle pattern - 1st floor bathroom under HA 2.



PHOTO: 2 **DATE: 6/12/2019** **BY: Greg Ross**
SUBJECT: HA 9: Presumed asbestos-containing duct wrap on a basement ventilation run.